


# MENSOLA 54 INCASSO 54 embedding bracket




PAG. 138

IEC 61537

1daN = 10 N = 1,0197 kg = 2.2461 lb

→ SWL pag. 13



<b>S</b>	<b>V</b>	<b>I</b>	Codice/ Code	Δ kg/pz	B mm	H mm	L mm	S mm	P daN	f* mm	Δ kg/pz	<b>Z</b>	Codice/ Code
A0	□	54U7X100K	0,17	50	50	100	1,5	120	4,4	0,18	A0 Z	54U7X100K	
A0	□	54U7X150K	0,24	50	50	150	1,5	120	5,1	0,25	A0 Z	54U7X150K	
A0	□	54U7X200K	0,30	50	50	200	1,5	120	6,0	0,32	A0 Z	54U7X200K	
A0	□	54U7X300K	0,43	50	50	300	1,5	120	7,4	0,45	A0 Z	54U7X300K	
A0	□	54U7X400K	0,68	50	75	400	1,5	120	8,5	0,72	A0 Z	54U7X400K	
A0	□	54U7X500M	1,11	50	75	500	2,0	100	8,6	1,16	A0 Z	54U7X500M	
A0	□	54U7X600M	1,32	50	75	600	2,0	100	9,9	1,38	A0 Z	54U7X600M	

\* Test eseguito con montaggio su profilato 34-C con S=2,5 mm / Test carried out with installation on channel 34-C with S=2,5 mm

□ Scegli il materiale/ Choose the material